

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/2022/ School/ W2/905


Dated: 18/8/2022

**FIRE SAFETY CERTIFICATE**

Certified that the Chand Ram Public (Sr. Sec.) School located at Nangal Thakran, Delhi-110039 is running on Single Block of Ground and First Floor only in a building comprised of Two Block of Ground + One upper floor owned/occupied by Chand Ram Public (Sr. Sec.) School was issued FSC by this department vide letter No. F6/DFS/MS/2019/1258 dated 12/06/2019. The premises was inspected by the officer concerned of this department on 16-08-2022 in the presence of Sh. Pawan Prakash(Manager) and observed that all the fire prevention and fire safety arrangement as provided in the permises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Education with effect from 18/8/2022. For a period of three years and subject to compliance of the conditions mentioned below.

Issued on 18/8/2022 at New Delhi

Yours faithfully

  
(Dharampal Bhardwaj)  
Dy Chief Fire Officer  
Delhi Fire Service

Copy to: -

1. Director of Education Govt. of NCT, Delhi, Old Secretariat, Delhi
2. The Principal, Chand Ram Public Sr. Sec. School, Nangal Thakran, Delhi-110039

**Condition for the validity of fire safety certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time.
2. Loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t construction etc. shall be verified by the concerned building sanctioning authority.
5. Second Block of Ground and First Floor shall not be used for school activity.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).