

No.DHO/NRZ/2025/184

Dated : 23/05/25

SCHOOL HEALTH CERTIFICATE

Date of Inspection : 23.05.2025

1. Name of the School : Chand Ram Public School

2. Address : Nangal Thakran, Delhi - 110039

3. No. of Shits : One Timing 08:00 A.M. to 02:00 P.M.

Accommodation Provided

THE FLOOR AREA IN THE CLASSROOM IS **SUFFICIENT**.

THE CLASSES ARE **WELL LIGHTED**.

THE CLASSROOMS ARE **WELL VENTILATED**.

THE CLASSROOMS ARE KEPT **NEAT & CLEAN**.

THE DRINKING WATER IS **DELHI JAL BOARD**.


THE TOILET ARRANGEMENT IS **SANITARY & HYGIENIC AND SUFFICIENT IN NUMBER**.

Remarks :

THIS CERTIFICATE DOES NOT INDICATE PERMISSIBILITY FROM LAND POINT OF VIEW.

The certificate is valid for one year from the date of issue.

The Principal
Chand Ram Public School
Nangal Thakran, Delhi - 110039


23/05/25
Dy. Health Officer
Narela Zone
Dy. Health Officer
Narela Zone

SAVE WATER, SAVE LIFE



DELHI JAL BOARD (GOVT. OF N.C.T. DELHI)
QUALITY CONTROL LABORATORY,
WATER TREATMENT PLANT BAWANA,
DELHI-110039.

Office of the A.C.W.A.
Diary No. 79
Date: 5/6/25

WTP Bawana
स्वच्छ भारत
एक कदम स्वच्छता की ओर

Water samples collected From Chand Ram Public (Sr.Secondary) School Nangal Thakran, Delhi-110039. vide Challan No.49 Dated 13.05.2025

S1: DIB Supply

S2: Drinking Point in the school premises

S. No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1	S2
			Acceptable	Permissible		
1.	Date of collection	--	---	---	28.05.2025	28.05.2025
2.	Date of Analysis	--	---	---	29.05.2025	29.05.2025
3.	Colour	C.U.	5	15	Clear	Clear
4.	Odour	--	Agreeable		Agreeable	Agreeable
5.	Turbidity	N.T.U	1.0	5.0	2.29	1.92
6.	pH value	--	6.5 to 8.5	N.R.	7.6	7.2
	Electrical Conductivity	umhos/cm	---	---	261.0	159.0
	Total Dissolved Solids	(mg/l)	500	2000	169.65	103.35
CHEMICAL EXAMINATION						
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil	Nil
10.	Total Alkalinity	(mg/l)	200	600	62.0	41.0
11.	Total Hardness	(mg/l)	200	600	98.0	68.0
12.	Calcium Hardness	(mg/l)	200	600	67.0	54.0
13.	Magnesium Hardness	(mg/l)	200	600	31.0	14.0
14.	Calcium as Ca	(mg/l)	75	200	26.8	21.6
15.	Magnesium as mg	(mg/l)	30	100	7.44	3.36
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND	ND
17.	Nitrite -Nitrogen (N)	(mg/l)	---	---	ND	ND
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	3.64	2.12
19.	Sulphate (SO ₄)	(mg/l)	200	400	41.09	26.23
20.	Chloride (Cl)	(mg/l)	250	1000	18.0	16.0
21.	Iron (Fe)	(mg/l)	1.0	N.R.	0.04	0.02
22.	Fluorides (F)	(mg/l)	1.0	1.5	0.29	0.24
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	Absent	Absent
24.	Residual Chlorine	(mg/l)	0.2	1.0	0.28	Nil
BACTERIOLOGICAL EXAMINATION						
25.	Coli form per 100 ml at 37°C	MPN/100 mL	0		0	0

Remarks: As per above tested parameters, Both Samples S1 and S2 found satisfactory and can be used for drinking purpose after proper disinfection.

Dilshy
Asst. Chemist/ Asst.Bacteriologist

Anam
5.6.25
Chemist/Bacteriologist

Alkh
06/6/25
A.C.W.A. (Bawana)